



Schenectady County
Purchasing Department
ADDENDUM

620 State St.-6th Floor
Schenectady, NY 12305
Purchasing@schenectadycounty.com
518.388.4242

RFB-2017-42
SCCC: SIDEWALK EXTENSIONS

ADDENDUM #1

August 1, 2017

The purpose of this addendum is to provide detailed information to all Bidders. This addendum is hereby included in and made part of the Contract Documents, whether or not attached thereto. The following changes to the specifications and/or drawings, shall prevail the original Contract Documents and all requirements of the original specifications and drawings shall remain in force except as amended by this Addendum. Receipt of this Addendum must be acknowledged on the bid form.

Clarifications:

1. The water valves are to remain in place and not be moved. Pour concrete around existing valves. Access to the valves is to remain.

General Questions:

1. Is curing spray acceptable for concrete curing?
Answer: *Yes, Refer to Specifications Section 03 30 00 Part 2, 2.1 Curing Materials*

Attachments:

Pre-Bid Walkthrough Sign-In Sheet

Apart from the items outlined in this addendum, all other provisions of the original scope shall remain in effect.

END OF ADDENDUM #1

RFB-2017-42

SCCC SIDEWALK EXTENSIONS

WALK-THROUGH

JULY 27, 2017 10:00 AM

NAME: Rick Garber

COMPANY: MCJ Construction LLC

EMAIL: rick.garber@mcjconstructionllc.com

PHONE: 518-661-5022 (cell 518-256-3248)

NAME: Nick Duncan

COMPANY: Callanan Industries

EMAIL: estimating@callanan.com

PHONE: 518-374-2222

NAME: Randy Bascom

COMPANY: R&B Cons.

EMAIL: randybascomconstruction@gmail.com

PHONE: 248-0493

NAME: Katie Talham
COMPANY: Bob Talham Inc.
EMAIL: Katie@TalhamInc.com
PHONE: 518-235-0267

NAME: JOSHUA FIELDS
COMPANY: COUNTY OF SCHENECTADY
EMAIL: JOSHUA.FIELDS@SCHENECTADYCOUNTY.COM
PHONE: 518.388.4200 x4568 or 518.545.8398

NAME: _____
COMPANY: _____
EMAIL: _____
PHONE: _____

NAME: _____
COMPANY: _____
EMAIL: _____
PHONE: _____