



Schenectady County
Purchasing Department
ADDENDUM

620 State St.-6th Floor
Schenectady, NY 12305
Purchasing@schenectadycounty.com
518.388.4242

RFB-2018-34
NISKAYUNA BRANCH LIBRARY – ROOF REPLACEMENT

ADDENDUM #1

July 20, 2018

The purpose of this addendum is to provide detailed information to all Bidders. This addendum is hereby included in and made part of the Contract Documents, whether or not attached thereto. The following changes to the specifications and/or drawings, shall prevail the original Contract Documents and all requirements of the original specifications and drawings shall remain in force except as amended by this Addendum. Receipt of this Addendum must be acknowledged on the bid form.

Attachments:

- Bid Form
- Pre-Bid Walkthrough Sign-In Sheet
- Added Drawing: A 03

Apart from the items outlined in this addendum, all other provisions of the original scope shall remain in effect.

END OF ADDENDUM #1



Schenectady County Request for Bid
 NISKAYUNA BRANCH LIBRARY – ROOF REPLACEMENT
 RFB-2018-34

Bid Form: Contractor

Bidder Name/Stamp: _____

A. PROJECT IDENTIFICATION:

RFB-2018-34: Niskayuna Branch Library – Roof Replacement

THIS BID IS SUBMITTED TO:

Schenectady County Purchasing
 620 State Street, 6th Floor
 Schenectady, New York 12305-2114
 (518) 388-4242

The undersigned BIDDER proposes and agrees, if this BID is accepted, to enter into an Agreement with COUNTY in the form included in the Contract Documents to complete all work as specified or indicated in the Contract Documents for the Contract Price and by the completion date indicated in the Agreement and in accordance with the Contract Documents.

BIDDER accepts all of the terms and conditions of the Instructions to Bidders, including without limitation those dealing with the disposition of Bid Security. This Bid will remain open for forty-five (45) days after the day of Bid opening. BIDDER will sign the Agreement and submit the Contract Security and other documents required by the Contract Documents within fifteen (15) days after the date of COUNTY'S Notice of Award.

BIDDER accepts all of the terms and conditions of the Instructions to Bidders, including without limitation those dealing with the disposition of Bid Security.

In submitting this BID, BIDDER represents that:

- (a) BIDDER has examined the site and locality where the work is to be performed, the legal requirements (federal, state, and local laws, ordinances, rules and regulations) and the conditions affecting cost, progress or performance of the work and has made such independent investigations as BIDDER deems necessary;
- (b) This BID is genuine and not made in the interest of or on behalf of any undisclosed person, firm or corporation and is not submitted in conformity with any Agreement or rules of any group, association, organization or corporation; BIDDER has not directly or indirectly induced or solicited or induced any person, firm or a corporation to refrain from bidding; and BIDDER has not sought by collusion to obtain for himself any advantage over any other BIDDER or over COUNTY;
- (c) BIDDER will complete the work for the prices listed in the Bid Schedule.
- (d) BIDDER HAS EXAMINED COPIES OF ALL THE CONTRACT DOCUMENTS;
- (e) BIDDER acknowledges the receipt of the following addenda and has included these requirements in the Bid. (If none, so state and affix signature).

Addendum #	Date



Schenectady County Request for Bid
NISKAYUNA BRANCH LIBRARY – ROOF REPLACEMENT
RFB-2018-34

Bid Form: Contractor

Bidder Name/Stamp: _____

BIDDER:

Legal Name of Person, Partnership, or Corporation

Authorized Signature

Type or Print Name

Date Submitted

BIDDER ADDRESS:

Street

City

State

Zip Code

Telephone Number

Facsimile Number

Email Address

Website

Federal Employer Identification Number

RFB-2018-34

NISKAYUNA BRANCH LIBRARY – ROOF REPLACEMENT



WALK-THROUGH

JULY 18, 2018 9:00 AM

NAME: M. LUCEY
COMPANY: Mid-State Inc.
EMAIL: Michael @ midstatehd.com
PHONE: 578-374-1461


NAME: JOSHUA FIELDS
COMPANY: COUNTY OF SCHENECTADY
EMAIL: JOSHUA.FIELDS @ SCHENECTADY COUNTY.COM
PHONE: (518) 545-8398

NAME: _____
COMPANY: _____
EMAIL: _____
PHONE: _____



PIPE PENETRATION



NOT DRAWN TO SCALE



- NOTES:
1. NOT ALL SHINGLES ARE SHOWN FOR CLARITY.
2. UNDERLAYMENT TYPE AND NECESSITY MAY VARY DEPENDING ON CLIMATIC CONDITIONS.

EAVE AND RAKE FLASHING

NOT DRAWN TO SCALE




- NOTES:
1. UNDERLAYMENT CAN BE INSTALLED ON TOP OF OR UNDER THE EAVE EDGE METAL FLASHING DEPENDING ON CLIMATIC CONDITIONS.
2. UNDERLAYMENT TYPE AND NECESSITY MAY VARY DEPENDING ON CLIMATIC CONDITIONS.
3. THIS DETAIL SHOWS ONE TYPE OF GUTTER SUPPORT. GUTTER SECUREMENT AND SUPPORT OPTIONS VARY ACCORDING TO REGIONAL PRACTICES AND MANUFACTURERS SPECIFICATIONS.

EAVE AND RAKE FLASHING WITH GUTTER

NOT DRAWN TO SCALE

GENERAL NOTES



1. REMOVE EXISTING ROOF FINISH AND SUBSTRATE DOWN TO EXPOSED STRUCTURE. PREP FOR NEW WORK
 - 1.1. ALT. NO. 1: REMOVE ENTIRE FASCIA SYSTEM IN ITS ENTIRETY AND REPLACE WITH COPPER.
 - 1.2. ALT. NO. 2: REMOVE ENTIRE FASCIA SYSTEM IN ITS ENTIRETY AND REPLACE WITH ALUMINUM
2. FURNISH AND INSTALL NEW ASPHALT SHINGLE ROOFING SYSTEM (LIFETIME). COLOR AS SELECTED BY OWNER
3. RIDGE VENT - HOLD PLYWOOD ROOF SHEATHING BACK 3/4" AT EACH SIDE OF ROOF
4. ICE AND WATER SHIELD
 - 4.1. ROOF EDGE: 24" TO THE INSIDE OF THE EXTERIOR WALL
 - 4.2. VALLEYS: 24" AT EACH SLOPING ROOF
5. SEE TYPICAL ROOF DETAILS



- NOTES:
1. FIELD UNDERLAYMENT NOT SHOWN FOR CLARITY.
2. VALLEY UNDERLAYMENT TYPE AND NECESSITY MAY VARY DEPENDING ON CLIMATIC CONDITIONS.
3. THE CUT SIDE OF THE VALLEY SHOULD BE ON THE SIDE WITH THE GREATEST AREA.

CLOSED CUT VALLEY



NOT DRAWN TO SCALE



- NOTES:
1. FIELD UNDERLAYMENT NOT SHOWN FOR CLARITY.
2. VALLEY UNDERLAYMENT TYPE AND NECESSITY MAY VARY DEPENDING ON CLIMATIC CONDITIONS.
3. SHINGLES SHOULD NOT BE FASTENED THROUGH METAL VALLEY.

OPEN VALLEY

NOT DRAWN TO SCALE



Office of Facilities

Project: RFB-2018-34

NISKAYUNA BRANCH LIBRARY - ROOF REPLACEMENT

Drawing Name:

DETAILS & NOTES

Drawn By: JRF

Date: JULY 2018

Drawing No.

A 03