

OCTOBER 24, 2019

SCHENECTADY COUNTY PURCHASING DEPARTMENT
620 STATE STREET, 6TH FLOOR
SCHENECTADY, NY 12305

AMENDMENT NO. 2 TO:

PROJECT: RIVER ROAD AND ROSENDALE ROAD INTERSECTION IMPROVEMENT
PROJECT, RFB-2019-49

IN THE LETTING OF
OCTOBER 29, 2019

NOTICE TO PROSPECTIVE BIDDERS

Questions

1. Q: Could you please clarify the location of the dry swale and if the dry swale excavation is excavation covered under item 206.0201?

A: The dry swale is the swale shown on the west and north side of the plunge pool on the northwest corner of the intersection and extends from approximately Sta. ROW 4+75LT to Sta. RI 3+75 RT. The dry swale excavation is paid for under item 206.0201.

2. Q: Can you please clarify if the truck apron is to have fiber reinforcement or welded wire fabric reinforcement? In addition, can you clarify if the truck apron is to have an exposed aggregate surface treatment?

A: The truck apron is to be constructed with welded wire fabric reinforcement instead of fiber reinforcement and to have an exposed aggregate finish.

Project Manual

1. A revised Bid Schedule has not been included. The Bidder shall REVISE the bid schedule to for item 601.01110001 to state a quantity of 914 SY.

Construction Plans

1. The bidder shall make the following changes to the contract plans:
 - On sheet number 5, the Bidder shall REVISE the Roundabout Typical Section so any areas that list ITEM 502.11111111 also list ITEM 601.01110001.
 - On sheet number 24, the Bidder shall REVISE Truck Apron Details so any areas that list ITEM 502.11111111 shall also list ITEM 601.01110001.

PLEASE BE GOVERNED ACCORDINGLY WHEN SUBMITTING BIDS.

PLEASE FILL IN AND SIGN BELOW AND FAX OR EMAIL A SIGNED COPY OF THIS SHEET BACK TO CREIGHTON MANNING AT (518) 446-0397 OR (CFarmer@cmellp.com) TO ACKNOWLEDGE RECEIPT OF THIS AMENDMENT.

PLEASE CONTACT CHARLES FARMER WITH CREIGHTON MANNING ENGINEERING AT (518) 689-1836 WITH ANY QUESTIONS.

Signed

Date

Representing

Thank you for your cooperation in this matter.