



Schenectady County
Purchasing Department
ADDENDUM

620 State St.-6th Floor
Schenectady, NY 12305
Purchasing@schenectadycounty.com
518.388.4240

RFB-2022-40
NISKAYUNA LIBRARY HVAC UPGRADES

ADDENDUM #1

3/28/2022

The purpose of this addendum is to provide detailed information to all Bidders. This addendum is hereby included in and made part of the Contract Documents, whether or not attached thereto. Receipt of this Addendum must be acknowledged on the bid form.

CONTENTS/RESPONSE TO QUESTIONS/REFERENCE TO ATTACHMENTS

Please acknowledge this addendum on your bid form.

Schenectady County Office of Facilities is making a change to the Equipment listed on Drawing M001.

Bidder to acknowledge that the Equipment listed below is furnished by Schenectady County and provided to the contractor for installation. Information listed below is for informational purposes only.

Equipment Purchased by the County Information Update:

For AHU-01/ACCU-01:

Qty. 1 Cooling Coil

Tag: AHU-01

Manufacturer: Trane

Coil for use in MCC Unit (MCCA)

Right Hand Supply

6 Rows

35" (889mm) Coil Height

59" (1499) Finned Length

Aluminum Fins

R-410A

Intertwined Circuits

Qty. 1: Odyssey Split System Outdoor Unit

Tag: ACCU-01

Manufacturer: Trane

Model: TTA18043CAB

6-25 Ton Unitary Split Systems Outdoor

RFB-2022-40 Addendum #1

Issued by Schenectady County Purchasing



Schenectady County
Purchasing Department
ADDENDUM

620 State St.-6th Floor
Schenectady, NY 12305
Purchasing@schenectadycounty.com
518.388.4240

Cooling (TTA)
15 Tons
R-410A Refrigerant
208-230/6/30
Manifold Compressors/Single Circuit
Electromechanical

Qty. 1: Heating Coil – Information to follow in next Addenda

For AHU-02/ACCU-02:

Qty. 1: Air Handler
Tag: AHU-02
Manufacturer: Carrier
Model: 39SHK02PZR2B4RDPFK
Packaged Air Handling Unit
The following items are included:
39S AHU 02 Vertical AHU
Unit Parameters
39S Air Handler Size 02
Orientation: Horizontal
Application: Indoor
Insulation: Standard Micromat Rx. 1 inch
2row Hot Water 4 row Direct Expansion Coils
Filter Track 2” merv8
39MA-410A040780308 – 4-T TXV Discharge 7/8”, Nozzle 3-8
AHU-2 Isolators – Spring Vibration Isolators.

Qty. 1: Condensing Unit
Tag: ACCU-02
Manufacturer: Carrier
Model: 24ABB336A005
Condensing unit ACCU 2 13Seer AC BASE 208/3 PHASE

END OF ADDENDUM #1